

Report No. W8MY502/PV/001
Type of examination Thorough and Working
Written Scheme No./Item No. WSE 001, 4/01
Date report issued 01.06.2018

Report of Examination of Pressure Vessel and Associated Protective Devices

Issued under and complies with -
Pressure Systems Safety Regulations 2000 (PSSR)

Issued by Rossendale Group Ltd., Portside North, Merseyton Road, Ellesmere Port, CH65 2HQ UK
T: +44(0)1513555091 F: +44(0)1513572108 E: sales@rossendalegroup.co.uk

Name and Address of User (installed systems), Owner (mobile systems) or Lessor (leased/hired systems)
MM Packaging Fourth Avenue Deeside CH5 2NR

Name of User and Address at which system is installed (leased systems) or located (mobile systems) if different
MM Packaging Fourth Avenue Deeside CH5 2NR

Site location	311 Machine
SYSTEM & PART IDENTIFICATION	WSE001 Air System, Air/Oil Receiver. P.E & Safety Valve, SN-95517
Product type	Air/Oil Receiver, Pressure Vessel
Description of equipment	Air/Oil Receiver, Pressure Vessel
Description of parts	Air/Oil Receiver, Pressure Gauge & Safety Valve
Identification of parts	A/01,SV2 PG 2
Manufacturer and DOM	Air Com - DOM - 2014
Standard or specification of manufacture	CE 0036
Date of last hydraulic test and pressure applied	N/A
Date and reference of relevant NDT	N/A
What parts were inaccessible?	Those enclosed due to construction. Internally inspected through pressure gauge opening.
EXAMINATION	
Detail type of examination	Thorough & Working
Detail tests carried out	Pressure gauge, safety valve removed, calibrated to RG certified test equipment
External condition	Good Order
Internal condition	Good Order
Exam results	Satisfactory
Have all the protective devices within the written scheme been examined?	Yes
State the condition of the protective devices	Good Order
REPAIRS	
Detail any repairs required	None
Date by which any repair should be completed	N/A
SAFE OPERATING LIMITS	
Other observations	Safety valve removed and tested, lifted at 13.5 ba
Are there any changes to the written scheme?	New Scheme prepared at time of examination
Details of written scheme changes	N/A
Reason for written scheme changes	No Scheme Available
AUTHENTICATION	

Date of authentication	01/06/2018
-------------------------------	-------------------

Examination & report by	A Fletcher
------------------------------------	-------------------

Date of examination	28/05/2018
----------------------------	-------------------

Signature of examiner	
------------------------------	---

Client P.O. Number	0019086
---------------------------	----------------

On behalf of competent person - Rossendale Group Ltd

DATES	Working	Thorough
Dates by which the next examination should be completed	28/05/2019	28/05/2023
Actual inspection date	28/05/2018	28/05/2018